

### CURRENT MONITORING





CUL US

# \Lambda DANGER 🆄

### HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

- Follow safe electrical work practices. See NFPA 70E in the USA, or applicable local codes.
- This equipment must only be installed and serviced by qualified electrical personnel.
- Read, understand and follow the instructions before installing this product.
- Turn off all power supplying equipment before working on or inside the equipment.
- Use a properly rated voltage sensing device to confirm power is off.
  DO NOT DEPEND ON THIS PRODUCT FOR VOLTAGE INDICATION
- Only install this product on insulated conductors.


### Failure to follow these instructions will result in death or serious injury.

# NOTICE

- This product is not intended for life or safety applications.
- Do not install this product in hazardous or classified locations.
- The installer is responsible for conformance to all applicable codes.

#### Mount this product inside a suitable fire and electrical enclosure.

### WIRING EXAMPLE



**UNIT VENT HEATER** 

# • Hawkeye ™ 800HV Split-Core Current Switch, Fixed Trip Point

#### Installer's Specifications

Sensor Power	Induced from monitored current
Insulation Class	600VAC RMS (UL)
Frequency Range	50/60 Hz
Temperature Range	-40° to 50°C (-40° to 122°F) (to 200A);
	-40° to 75°C (-40° to 167°F) (to 100A & 0.25A output)
Humidity Range	10-90% RH, non-condensing
Output	N.O. 500mA@250VAC/DC, polarity insensitive
Amperage Range	0.75-200A Continuous
Terminal Block Maximum Wire Size	14 AWG
Terminal Block Torque (nominal)	4 in-lbs (0.45 N-m)
Agency Approvals	UL 508 open device listing


The product design provides for basic insulation only.

## **INSTALLATION**

# Disconnect and lock out power to the enclosure containing the conductor to be monitored.

- Locate a mounting surface for the removable mounting bracket that will allow the monitored conductor to pass through the center window when it is installed and that will keep the device at least 1/2" from any uninsulated conductors. Determine cable routing for the output connection, allowing wiring to reach the mounting location.
- 2. Drill holes to mount the bracket to the chosen surface using the included screws.
- 3. Wire the output connections and relay between the sensor and the controller (solid-state contact) and external power supply.
- 4. Route the conductor through the sensor's center window and slip the assembly into the mounting bracket.
- 5. Secure enclosure and reconnect power.

### **DIMENSIONS**



# information@itm.com

## 1.800.561.8187






### **OPERATION**

The H800HV is a current-sensitive switching device that monitors current (amperage) in the conductor passing through it. A change in amperage in the monitored conductor that crosses the switch (setpoint) threshold plus the hysteresis value will cause the resistance of the FET status output to change state, similar to the action of a mechanical switch. In this model, the setpoint is fixed at 750mA AC max. The status output is suitable for connection to building controllers or other appropriate data acquisition equipment with inputs up to 250 volts. The H800HV requires no external power supply to generate its output.

### NOTES

#### For load currents greater than sensor maximum rating:

Use a 5 Amp (H68xx series) Current Transformer (CT) as shown. This technique can be combined with wrapping (see below) when added range is desired for a low current load on a high current source.



 $\triangle$ 

DANGER: 5A CTs can present hazardous voltages. Install CTs in accordance with manufacturer's instructions. Terminate the CT secondary before applying current.

## CAUTION

#### **RISK OF EQUIPMENT DAMAGE**

• Derate the product's maximum current for the number of turns through the sensing window using the following formula.

Rated Max. Amps  $\div$  Number of Turns = Max. monitored Amps

e.g. :  $100A \div 4$  Turns = 25 Amps max. in monitored conductor


• Failure to follow these instructions can result in overheating and permanent equipment damage.

#### For load currents less than sensor minimum rating:

Wrap the monitored conductor through the center window and around the sensor body to produce multiple turns through the center window. This increases the current measured by the transducer.

Program controller to account for the extra turns. e.g., if four turns pass through the sensor (as shown) divide the normal controller reading by 4.





# 1.800.561.8187

## TROUBLESHOOTING

Problem	Solution
No Reading at Controller	Check for control voltage at sensor (<250V)  Check for amperage in monitored conductor (> 0.75A  @ 60Hz)



# information@itm.com